Selectmen
Lee Bryant, Chair
Patricia Eldrigde, Vice
John Williams II
Greg Newell
Steve Armenia

Town of Clifton
135 Airline Road
Clifton, Maine 04428
(207) 843-0709
townoffice@cliftonme.com

CEMETERY ROADWAY REHABILITATION
ADDENDUM A

1. "What thickness is the Propers looking for?"

Place Grade A, 2-inch minus aggregate to a compacted depth of approximately 2 to 3 inches over the roadway areas shown in Appendix A.

2. "What does it mean by 'Unit' in SECTION 6. - PROPOSAL FORM?"

In the Price Schedule two items are listed, one line for each cemetery (in no particular order):

- Maple Wood Cemetery, Route 180, Clifton, ME.
- Mt. Pleasant Cemetery (approximately), 741 Airline Rd, Clifton, ME

Enter a single lump sum price for all work at Maple Wood Cemetery on one line and at Mt. Pleasant Cemetery on the other and repeat each price in the Extended Total column. The Total Proposal Price is the sum of the two items.

3. Section 6 Proposal Form

On page one, the second paragraph from the bottom, the first sentence should read:
"The undersigned further agrees that, if the Town accepts this Proposal within thirty (30) days from the date of opening of the Proposals and sufficient funds are appropriated for the Services, it will execute the Services Agreement and deliver the documents required by Section ~~2.13~~ **2.14** of the Instructions to Proposers, including certificates of insurance, any required bonds, and a completed IRS Form W-9, within the time stated there."